Built-up cladding products, veture, cladding products and soffit products

**Technical document 15-02** 

Relative to veture products.

The English version is provided for information. In case of doubt or dispute, the French version only is valid

Technical document 15-05 rev 01 04/08/2023





CSTB/(Centre Scientifique et Technique du Bâtiment), a public establishment supporting innovation in construction, has four key activities: research, expertise, assessment and dissemination of knowledge, organised to meet the challenges of ecological and energy transition in the construction sector. Its field of competence covers construction materials, buildings and their integration into districts and towns.

With over 900 employees, its subsidiaries and networks of national, European and international partners, the CSTB group works for all the stakeholders in the construction sector to push forward the quality and safety of buildings.

All reproduction or representation, complete or partial, by whatever means, of the pages published in this technical document and executed without the authorisation of CSTB is illegal and constitutes forgery. The only authorised exceptions are reproductions strictly reserved for the use of the typist and not for the purpose of any collective use; or analyses and short quotations required due to the scientific or information nature of the work in which they figure (article L.122-5 of the Intellectual Property Code). This document has been drawn up under the initiative and direction of CSTB, which has brought together the opinions of all interested parties

© CSTB





# **HISTORIC OF MODIFICATION**

N° de révision	Date application	Modifications
00	28/02/2018	Creation
01	04/08/2023	Added historical table of changes, editorial revisio



# **TABLE OF CONTENTS**

Pa	rt 1	Organisation	5
Pa	rt 2	Technical file per product family for built-up cladding and soffits	8
A	۹.	Polystyrene or rockwool insulation	8
	A1.	CEMENT OR HYDRAULIC MORTAR FACING	8
	A2.	GLASS FIBRE REINFORCED CEMENT FACING	10
	A3.	FIBRE CEMENT FACING	11
	A4.	POLYESTER RESIN COMPOUND FACING	12
	A5.	ALUMINIUM SHEET FACING	13
	A6.	CLAY SLIP FACING	14
	A7.	CLAY SLIP FACING	15
E	3.	Polyurethane insulation	16
	B1.	CLAY SLIP FACING	16
	B2.	ALUMINIUM SHEET FACING	17
	В3.	POLYESTER RESIN COMPOUND	18
	B4.	PVC-U RIGID RESIN COMPOUND	20
	B5.	EXPANDED OR CO-EXTRUDED PVC-UE RESIN COMPOUND	22
	B6.	ROCKWOOL/THERMOSETTING RESINS	24
	B7.	POLYESTER RESIN LAMINATE + CEMENT OR HYDRAULIC MORTAR	25
	B8.	RESIN MORTAR - GLASS FACING	26
(	<b>C</b> .	Hydraulic mortar	28
	C1.	HYDRAULIC MORTAR	28
	C2.	GLASS FIBRE REINFORCED CEMENT	29
	C3.	FIBRE CEMENT	31
	C4.	CEMENT MORTAR AND CLAY SLIPS	33
[	<b>)</b> .	Clay and ceramic	34
E	Ξ.	Composite panels and composite panels with metal facing	36
	E1.	ALUMINIUM SHEET AND POLYURETHANE LAYER COMPOSITE PANEL	36
	E2.	ALUMINIUM SHEET AND POLYETHYLENE COMPOSITE PANEL	37
	E3.	COMPOSITE PANEL OF STEEL SHEET AND VARIOUS CORES	39
	E4.	COMPOSITE PANEL OF STONE AND VARIOUS CORES	
F	Ξ.	Thermally modified natural wood	42
(	3.	Natural stone	43



# Part 1 Organisation

This technical document defines for each product or procedure:

- The certified characteristics;
- The product evaluation method;
- The classification of the standard;
- The list of available standards.

For the standards that indicate a date of application or an index, only the version cited is applicable. For standards that do not indicate a date of application or index, the most recent version of the reference document applies (including any amendments).

#### Certified characteristics:

- Dimensions;
- Composition;
- The certified characteristics, depending on the product, are as follows:
  - resistance to perpendicular tensile force of the venture facing on the insulation,
  - pull-out strength of the fastening points provided in the veture facing,
  - pull-out strength of the fastening points provided in the insulation of the veture,
  - pull-out strength of the fastening groove provided in facing of the veture,
  - pull-out strength of the fastening groove provided in the insulation of the veture,
  - all other mechanical characteristics necessary to corroborate the mechanical strength of the veture element.

The mechanical characteristics related to the installation of the product are described in § 5.4.2. of the European Technical Approval Guideline (ETAG 17) for vetures

Supplementary characteristics in the technical file of the assessment of fitness for use (ATEC, DTA, ATEx, etc.) may also be covered in the certificate.



A statistical analysis annually or between each audit is to be set up by the holder for the certified characteristics with at least the number of inspections conducted, the arithmetic mean, the standard deviation and the mean with a confidence level of at least 95% calculated according to Standard ISO 2602

The records over a period equal to that elapsed between two audits and at least 1 year shall be available on the day of the audit in order to be sampled.

The records of the certified characteristics are archived for at least 10 years

#### INFORMATION RELATIVE TO CE MARKING

#### Reference documents

- Type test reports used as justification for the CE marking by the standards-related method:
- Currently-valid European Technical Approval or European Technical Assessment issued for the product and its evaluation report;
- Certificate of conformity issued by an authorised body or attestation of conformity prepared by the manufacturer.

#### Class required by the Harmonised Standard

If a class is required by the Harmonised Standard for applications of the product outdoors (such as built-up cladding products, cladding products or soffit products), this requirement is re-stated in the admission procedures.

In no case may the product have certified characteristics less than the characteristics required for the declared use as part of CE marking

#### **Product covered under an EAD**

For products not coming under a Harmonised Standard, the implementation of the CE Marking is covered by European Technical Approval Guideline (ETAG) 17 for veture kits or an EAD.

Test standards are listed for the products concerned in Appendix B of the Guide.

The submission of an ETA application for products coming under an EAD is a voluntary procedure



#### Additional non-certified characteristics

These characteristics are selected to corroborate the fitness for use of the product in a system of built-up cladding, cladding products and soffit products.

These tests and the minimum frequencies concern, for all the product families:

- Dimensional inspections: at each production run start or change, at least once per shift;
- Functional inspections: at each production run start or change, at least once per shift;
- Visual appearance inspections (colour, surface state compliance): on all the elements;
   other ways and means can be used at frequencies defined by the manufacturer to check the colour, the gloss or the relief of the facing;
- Specific inspections: the inspections are defined in relation to the normative frame of reference of the product family and are indicated in its family-specific appendix. The test frequencies are also indicated therein.

The functional inspections cover the geometrical aspects for a satisfactory installation of the product (square, flatness, straightness of the edges, profiles of the element, mate fitting, dimension and position of groove, etc.); at each production run start-up or change, at least once per shift.

The specific inspections are physical-chemical inspections (water absorption, resistance to frost, etc.) or durability inspections (heat shrinkage, resistance to boiling water) to detect any abnormal deviation in the behaviour of the finished product.

Additional specific tests or documentary inspection of the internal procedures are required for the following situations:

- The element is equipped with a surface coating, applied by the manufacturer that may
  present a risk of detachment: inspection of the adhesion of the coating to the substrate;
  at each production run start-up or change, at least once per shift; this inspection is
  proposed by the manufacturer given its experience in the field;
- Proficiency in bonding the insulation on the back of the facing;
- Proficiency in painting the elements.

These aspects (the list of which is not exhaustive) are covered by the audit

The fitness of the use of the insulating material in the product is part of the procedure for issuing the Technical Assessment or ETA of the veture.



# Part 2 Technical file per product family for built-up cladding and soffits

## A. Polystyrene or rockwool insulation

#### A1. CEMENT OR HYDRAULIC MORTAR FACING

#### Product evaluation method

Product family that may come under an ETA.

- Flexural strength and modulus according to Standard NF EN 14617-2;
- Apparent density and water absorption coefficient according to Standard NF EN 14617 1:
- Freeze-thaw resistance according to Standard NF EN 14617-5;
- Thermal shock resistance according to Standard NF EN 14617-6;
- Linear thermal expansion coefficient according to Standard NF EN 14617-11;
- Tolerances for dimensions, geometrical characteristics and surface quality of modular tiles according to Standard NF EN 14617-16.



§	Inspections	Frequencies
A1.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.) Inspection of machining of the groove (according to the installation)	At each change and random sampling once per shift
A1.2.	Inspection of visual appearance	Each panel
A1.3.	Resistance to perpendicular tensile force according to method B2 of DT 15-03 (if the strength of the groove in the insulation is certified)	Once a month
	Certified characteristics	
A1.4.	Composition Thickness Flexural strength according to DT 15-03 method 2.1 or Strength of the groove DT 15-03 method 2.5(according to the installation) If groove in insulation: Resistance to perpendicular tensile force according to DT 15-03 method 2.2	Once a week with recording



#### A2. GLASS FIBRE REINFORCED CEMENT FACING

#### Product evaluation method

Product family that may come under an ETA.

#### Standards available

- Consistency of the matrix, "Slump test" method, according to Standard NF EN 1170-1;
- Fibre content according to Standard NF EN 1170-2;
- Flexural strength according to Standard NF EN 1170-5;
- Dry density and water absorption according to Standard NF EN 1170-6;
- Extremes of dimensional variations due to moisture content according to Standard NF EN 1170-7;
- Cyclic weathering test method according to Standard NF EN 1170-8;
- Freeze-thaw resistance according to Standard NF EN 14617-5;
- Thermal shock resistance according to Standard NF EN 14617-6;
- Linear thermal expansion coefficient according to Standard NF EN 14617-11;
- Tolerances for dimensions, geometrical characteristics and surface quality of modular tiles according to Standard NF EN 14617-16.

Considerity of Sen inspection of production in the rectory			
§	Inspections	Frequencies	
A2.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, etc.) Inspection of machining the groove in the facing (according to the installation)	At each change and random sampling once per shift	
A2.2.	Inspection of visual appearance	Each panel	
A2.3.	Resistance to perpendicular tensile force according to method A2 of DT 15-03	Once a month	
	Certified characteristic	es ·	
A2.4.	Composition Thickness Flexural strength according to Standard NF EN 1170-5 or Flexural strength according to DT 15-03 method 2.1	Once a week with recording	



#### A3. FIBRE CEMENT FACING

#### Product evaluation method

Product family that may come under an ETA.

Product reference documents used for the facing of the veture: STANDARD NF EN 12467

#### Classification according to the standard

The product class according to Standard EN-12467 is described in § 5.2.

Weather resistance category: A for severe external grade.

Category of tolerances on the nominal dimensions: Level 1.

N.B. the "CERTIFIÉ CSTB CERTIFIED" mark of fibre-cement flat sheets applies, on the date of approval of this reference system, to NT type products only, due to decree no. 96-1133 of 24 December 1996 on the asbestos ban.

#### Standards available

- Geometric tests according to § 7.2. of Standard NF EN 12467;
- Functional inspections according to § 7.2. of Standard NF EN 12467;
- Wet density and flexural strength in wet conditions according to standard NF EN 12467;
- Dry density and watertightness according to § 7.3 of Standard NF EN 12467;
- Climatic performance tests according to § 7.4. of Standard NF EN 12467.

§	Inspections	Frequencies
A3.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, etc.)	At each change and random sampling once per shift
A3.2.	Inspection of visual appearance	Each panel
A3.3.	Resistance to perpendicular tensile force according to method A2 of DT 15-03	Once a month
	Certified characteristics	
A3.4.	Composition Thickness Flexural strength in wet conditions according to Standard NF EN 12467	Once a week with recording



#### A4. POLYESTER RESIN COMPOUND FACING

#### Product evaluation method

Product family that may come under a Technical Assessment or an ETA.

#### Standards available

- Flexural strength according to Standard NF EN ISO 14125;
- Mass per unit area according to Standard NF EN ISO 10352;
- Glass content according to Standard NF EN ISO 1172;
- Hardening characteristics according to Standard NF EN ISO 584 or NF EN ISO 12114;
- Barcol hardness according to Standard NF T 57-106;
- Method of exposure to Xenon-arc sources according to standards NF EN ISO 4892-1 and 2;
- Method of exposure to natural ageing according to Standard ISO 4607.

§	Inspections	Frequencies	
A4.0.	Glass content Reactivity	Twice a year*	
A4.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.) Barcol hardness test according to NF T 57-106	At each change and random sampling once per shift	
A4.2.	Inspection of visual appearance	Each panel	
A4.3	Resistance to perpendicular tensile force according to method A2 of DT 15-03	Once a month	
	Certified characteristics		
A4.4.	Composition Thickness or weight per m² Flexural strength according to Standard NF EN ISO 14125	Once a week with recording	

<sup>\*</sup> Tests that can be carried out by the supplier if the manufacturer of the cladding strips purchases the raw material from a supplier that makes the compound to order at the manufacturer's request.



#### A5. ALUMINIUM SHEET FACING

#### **Product evaluation method**

Product family that may come under an ETA.

Product reference documents used for the facing of the veture: NF EN 14782

## Classification according to the standard

The minimum requirements are given in § 4 of Standard NF EN 14782.

Minimum nominal specified thickness of the metal sheet in mm: 0.4.

#### Standards available

- Dimensional tolerances: Appendix B of Standard NF EN 508-2.

§	Inspections	Frequencies	
A5.0.	Acceptance certificate 3.1. A according to standard EN 10204	At each delivery	
A5.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.) Profile geometry	At each change and random sampling once per shift	
A5.2.	Inspection of visual appearance	Each panel	
	Certified characteristics		
A5.3.	Composition Thickness Flexural shear strength according to Appendix A3 of Standard NF EN 14509	Once a week with recording	



#### A6. CLAY SLIP FACING

#### Product evaluation method

Product family that may come under an ETA

#### Standards available

- Determination of core density according to Appendix A8 of Standard EN 14509;
- Mechanical strength tests on the panels: Appendices C3 and C4 of European Technical Approval Guideline no.16 (self-supporting composite lightweight panels);
- Tests on assembling devices, § 5.4.2. of European Technical Approval Guideline no. 17;
- Specifications and test methods for clay wall slips according to Standard NF P 13-307.

8	Inspections	Frequencies	
A6.0	Check of the colour and appearance of the slips	At each delivery	
A6.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift	
A6.2.	Inspection of visual appearance and defects (bloom, bursting, cracking, etc.)	Each panel	
	Certified characteristics		
A6.3.	Composition Thickness Resistance to perpendicular tensile force of the facing according to DT 15-03 method 2.3 Compressive strength of fastening indentations of the veture according to DT 15-03 method 2.4	Once a week with recording	



#### A7. CLAY SLIP FACING

#### **Product evaluation method**

Product family that may come under an ETA.

#### Standards available

- Requirements for stone used for cladding according to Standard EN 1469;
- Density and porosity according to Standard NF EN 1936;
- General prescriptions for use of natural stones according to Standard NF B 10-601;
- Flexural strength according to Standard NF EN 12372;
- Frost resistance according to Standard NF EN 12371;
- Breaking load at dowel hole according to Standard NF EN 13364.

§	Inspections	Frequencies
	Documented internal procedure for acceptance inspection of stones	At each delivery
A7.0.	Porosity and apparent density according to Standard NF EN 1936	Once every two years
	Flexural strength according to standard NF EN 12372	Once every two years
A7.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift
A7.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
A7.3.	Thickness Geometrical inspection of the groove (if fitted in continuous rabbet) or Resistance of the catches according to DT 15-03 method 1.9	Once a week with recording



## B. Polyurethane insulation

#### **B1.** CLAY SLIP FACING

#### **Product evaluation method**

Product family that may come under a Technical Assessment or an ETA.

#### Standards available

- Determination of core density according to Appendix A8 of Standard EN 14509;
- Mechanical strength tests on the panels: Appendices C3 and C4 of European Technical Approval Guideline no.16 (self-supporting composite lightweight panels);
- Tests on assembling devices, § 5.4.2. of European Technical Approval Guideline no. 17 (Vetures);
- Specifications and test methods for clay wall slips according to Standard NF P 13-307.

§	Inspections	Frequencies	
B1.0.	Check of the colour and appearance of the slips	At each delivery	
B1.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift	
B1.2.	Inspection of visual appearance and defects (bloom, bursting, cracking, etc.)	Each panel	
	Certified characteristics		
B1.3.	Composition Thickness Resistance to perpendicular tensile force of the facing according to DT 15-03 method 1.2 Compressive strength of fastening indentations of the veture according to DT15-03 method 2.4	Once a week with recording	



#### **B2. ALUMINIUM SHEET FACING**

#### **Product evaluation method**

Product family that may come under a Technical Assessment.

#### Standards available

- Determination of core density according to Appendix A8 of Standard EN 14509;
- Mechanical strength tests on the panels: Appendices C3 and C4 of European Technical Approval Guideline no.16 (self-supporting composite lightweight panels);
- Tests on assembling devices, § 5.4.2. of European Technical Approval Guideline no. 17 (Vetures).

§	Inspections	Frequencies
B2.0.	Acceptance certificate 3.1. A according to Standard EN 10204	At each delivery
B2.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.) Longitudinal deflection	At each change and random sampling once per shift
B2.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
B2.3.	Composition Thickness or mass per unit area Flexural shear strength according to Appendix A3 of Standard NF EN 14509	Once a week with recording



#### B3. POLYESTER RESIN COMPOUND


#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

- Flexural strength according to Standard NF EN ISO 14125;
- Mass per unit area according to Standard NF EN ISO 10352;
- Glass content according to Standard NF EN ISO 1172;
- Hardening characteristics according to Standard NF EN ISO 584 or NF EN ISO 12114;
- Barcol hardness according to Standard NF T 57-106;
- Method of exposure to natural ageing according to Standard ISO 4607;
- Method of exposure to Xenon-arc sources according to standards NF EN ISO 4892-1 and 2.





§	Inspections	Frequencies
B3.0.	Glass content Reactivity	Twice a year*
B3.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.) Barcol hardness test according to Standard NF T 57-106 or impact strength (D0.5,1 J) according to in-house method	At each change and random sampling once per shift
B3.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
B3.3.	Composition Thickness or weight per m² Flexural strength according to standard NF EN ISO 14125 or Maximum moment of the panel calculated for the unit of width according to DT 15-03 method 2.1 on the vetures.	Once a week with recording

<sup>\*</sup> Tests that can be carried out by the supplier if the manufacturer of the cladding strips purchases the raw material from a supplier that makes the compound to order at the manufacturer's request.



#### B4. PVC-U RIGID RESIN COMPOUND

Reference document: STANDARD NF EN 13245-2

## Classification according to the standard

Characteristics	Test method	Property or attribute Unit	Class
Impact strength	EN 13245-1 Appendix A	Temperature (T), °C and Energy (J), Joules	(T, J) min. code (23, 01)
Resistance to artificial ageing (A for artificial) or Resistance to natural ageing (N for natural)	Method A of standard EN ISO 4892-2:1999 or In listed sites, at 45° facing south	Total radiation GJ/m² (n) and Temperature (T), °C or Total radiation GJ/m² (n) and Temperature (T), °C	A, n, T or N, n, T
Impact strength after artificial ageing or Impact strength after natural ageing	EN 13245-1 appendix A	Temperature (T), °C and Duration (h), hour or Total radiation GJ/m² (n) and Temperature (T), °C	A, h, T min. code (A, 2, 23) or N, n min. code (N, 2)

- Density at 23°C according to Standard NF EN ISO 1183;
- Ash content according to Standard NF EN ISO 3451-5;
- Flexural strength and flexural modulus according to Standard NF EN ISO 527-2;
- Impact resistance according to Appendix A of Standard EN-13245-1;
- Method of exposure to natural ageing according to Standard ISO 4607;
- Method of exposure to Xenon-arc sources according to standards NF EN ISO 4892-1 and 2.





§	Inspections	Frequencies	
B4.0.	Density at 23°C Ash content	Twice a year*	
B4.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.)	At each change and random sampling once per shift	
B4.2.	Inspection of visual appearance	Each panel	
B4.3	$\begin{array}{llllllllllllllllllllllllllllllllllll$	Once a week	
	Certified characteristics		
B4.4.	Composition Thickness or weight per linear metre Stress at yield point and % elongation at break according to Standard NF EN ISO 527-2	Once a week with recording	

<sup>\*</sup> Tests that can be carried out by the supplier if the manufacturer of the cladding strips purchases the raw material from a supplier that makes the compound to order at the manufacturer's request.




#### B5. EXPANDED OR CO-EXTRUDED PVC-UE RESIN COMPOUND

Reference document: STANDARD NF EN 13245-2

## Classification according to the standard

Characteristics	Test method	Property or attribute Unit	Class
Impact strength	EN 13245-2 Appendix B	Temperature (T), °C and Energy (J), Joules	(T, J) min. code (23,01)
Resistance to artificial ageing (A for artificial) or Resistance to	Method A of standard EN ISO 4892-3: 1999 method 3, exposure no. 1 or	Duration (h), hour and Temperature (T), °C or	A, h, T or
natural ageing (N for natural)	In listed sites at 45° facing south	Total radiation GJ/m² (n) and Temperature (T), °C	N, n, T
Impact strength after artificial ageing or Impact strength after natural ageing	EN 13245-2 Appendix B	Temperature (T), °C and Duration (h), hour  or  Total radiation GJ/m² (n) and Temperature (T), °C	A, h, T min. code (A, 2, 23) or N, n, T min. code (N, 2, 23)

- Density at 23°C according to Standard NF EN ISO 1183;
- Ash content according to Standard NF EN ISO 3451-5;
- Flexural strength and flexural modulus according to Standard NF EN ISO 178;
- Impact resistance according to Appendices B and D to Standard EN-13245-2;
- Method of exposure to natural ageing according to Standard ISO 4607;
- Method of exposure to Xenon-arc sources according to standards NF EN ISO 4892-1;
- Artificial Ageing: Method A of Standard EN ISO 4892-3: 1999.





§	Inspections	Frequencies
B5.0.	Density at 23°C (core and skin) Ash content (core and skin)	Twice a year*
B5.1.	Dimensional inspections (length, width)  Functional inspections (flatness, squareness, mate fitting, etc.)	At each change and random sampling once per shift
	Thickness of the skin (for coextruded)	
B5.2.	Inspection of visual appearance	Each panel
B5.3	Impact strength (energy $\geq$ 5 Joules, $t \leq 0$ °C)	Once a week
	Certified characteristics	
B5.4.	Composition Thickness or weight per linear metre Flexural modulus according to Standard NF EN ISO 178	Once a week with recording

<sup>\*</sup> Tests that can be carried out by the supplier if the manufacturer of the cladding strips purchases the raw material from a supplier that makes the compound to order at the manufacturer's request.



## **B6.** ROCKWOOL/THERMOSETTING RESINS

#### **Product evaluation method**

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

Standards available: No reference documents applicable.

§	Inspections	Frequencies	
B6.0.	Resistance to light under xenon arc lamp after 3,000 h of exposure (6 MJ/m²) according to the procedures in Standard NF EN 438-2 (Part 28), greyscale assessment (Standard EN 20105-A02) $\geq$ 3	Each time a new colour goes into production	
B6.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, etc.) Check of loss on ignition check (in-house method)	At each change and random sampling once per shift	
B6.2.	Inspection of visual appearance	Each panel	
B6.3	Water absorption test (in-house method) Check of swelling after immersion according to Standard NF EN 317 or or Check of transverse tensile strength after immersion in boiling water according to Standard NF EN 1087-1, then Standard NF EN 319	Per production run and sampling once a month	
	Certified characteristics		
B6.4	Thickness Check of apparent density according to Standard NF EN 323 Check of flexural strength according to Standard NF EN 310	Per production run and random sampling once a week	



#### B7. POLYESTER RESIN LAMINATE + CEMENT OR HYDRAULIC MORTAR

#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Flexural strength according to Standard NF EN ISO 14125;
- Mass per unit area according to Standard NF EN ISO 10352;
- Glass content according to Standard NF EN ISO 1172;
- Reactivity according to Standard NF EN ISO 584 or NF EN ISO 12114.

§	Inspections	Frequencies	
B7.0.	Glass content in the polyester laminate Reactivity of the polyester laminate	Twice a year*	
B7.1.	Dimensional inspections (length, width) Functional inspections (straightness of edges, squareness, etc.)	At each change in dimension and/or raw material, and random sampling once per shift	
B7.2.	Inspection of visual appearance	Each panel	
B7.3.	Flexural strength according to method A4 of DT 15- 03	Once a month	
	Certified characteristics		
B7.4.	Composition Thickness or weight per m² Pull-off strength of the facing on a composite built- up cladding or cladding element according to DT 15-03 method 1.5	Once a week with recording	

<sup>\*</sup> Tests that can be carried out by the supplier if the manufacturer purchases the raw material from a supplier that, at the manufacturer's request, makes the compound or composite panel to order.



#### B8. RESIN MORTAR - GLASS FACING


#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

- Flexural strength according to Standard NF EN ISO 178;
- Mass per unit area according to Standard NF EN ISO 10352;
- Glass content according to Standard NF EN ISO 1172;
- Barcol hardness according to Standard NF T 57-106;
- Reactivity according to Standard NF EN ISO 584 or NF EN ISO 12114;
- Evaluation of conformity of toughened soda lime silicate safety glass according to Standard EN 12150-2.





§	Inspections	Frequencies
B8.0.	Glass content of the mortar Reactivity CE mark certificate of compliance of the glass facing	Twice a year
B8.1.	Dimensional inspections of mortar-on-insulation (length, width, thickness).  Barcol hardness test of mortar-on-insulation according to Standard NF T 57-106 or other means.  Functional inspections of mortar-on-insulation (flatness, squareness, etc.).  Inspection of position of fastenings on mortar-on-insulation.  Inspection of bonding adhesive (reactivity, hardness and ratio)  Bonding adhesive test (thickness and spread)  Testing functional and dimensional quality on finished products (length, width, total thickness and component thicknesses, flatness, squareness, position of the fixing system)	At each change and random sampling once per shift
B8.2.	Flexural strength of the mortar-on-insulation according to Standard NF EN ISO 178	Once a week with recording
B8.3.	Inspection of visual appearance	Each panel
	Certified characteristics	
B8.4.	Composition Total and component thicknesses Pull-off strength of the facing according to DT 15-03 method 1.5.	Once a week with recording



## C. Hydraulic mortar

#### C1. HYDRAULIC MORTAR

#### **Product evaluation method**

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Flexural strength and modulus according to Standard NF EN 14617-2;
- Apparent density and water absorption according to standard 14617-1;
- Freeze-thaw resistance according to Standard NF EN 14617-5;
- Thermal shock resistance according to Standard NF EN 14617-6;
- Linear thermal expansion coefficient according to Standard NF EN 14617-11;
- Tolerances for dimensions, geometrical characteristics and surface quality of modular tiles according to Standard NF EN 14617-16.

§	Inspections	Frequencies
C1.1.	Dimensional inspections (length, width)  Functional inspections (flatness, squareness, etc.)  Inspection of machining of the groove (according to the installation)  Inspection of positioning of the fasteners or inserts (according to the installation)	At each change and random sampling once per shift
C1.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
C1.3.	Composition Thickness Flexural strength according to Standard NF EN 14617-2 and Pull-out strength of fasteners or inserts	Once a week with recording



#### C2. GLASS FIBRE REINFORCED CEMENT

#### **Product evaluation method**

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

- Consistency of the matrix, "Slump test" method, according to Standard NF EN 1170-1;
- Fibre content according to Standard NF EN 1170-2;
- Flexural strength according to standards NF EN 1170-4 and 5;
- Dry density and water absorption according to Standard NF EN 1170-6;
- Extremes of dimensional variations due to moisture content according to Standard NF EN 1170-7;
- Cyclic weathering test method according to Standard NF EN 1170-8;
- Freeze-thaw resistance according to Standard NF EN 14617-5;
- Thermal shock resistance according to Standard NF EN 14617-6;
- Linear thermal expansion coefficient according to Standard NF EN 14617-11;
- Tolerances for dimensions, geometrical characteristics and surface quality of modular tiles according to Standard NF EN 14617-16.



§	Inspections	Frequencies
C2.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, etc.) Inspection of machining of the groove (according to the installation) Inspection of positioning of the fasteners or inserts (according to the installation)	At each change and random sampling once per shift
C2.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
C2.3.	Composition Thickness Flexural strength according to Standard NF EN 1170-5 and Pull-out strength of fasteners or inserts	Once a week with recording



#### C3. FIBRE CEMENT

Reference document: STANDARD NF EN 12467

#### Classification according to the standard

The mechanical strength class is defined in Standard EN 12467 and applies to finished products ready for delivery

Weather resistance category: A for severe external grade.

Category of tolerances on the nominal dimensions: Level 1.

<u>N.B.</u> The QB mark of fibre-cement flat panels applies, on the date of approval of this reference system, to NT type products only, due to decree no. 96-1133 of 24 December 1996 relating to the asbestos ban.

#### Standards available

- Geometric tests according to Standard NF EN 12467;
- Functional tests according to Standard NF EN 12467;
- Wet density and flexural strength in wet conditions according to standard NF EN 12467;
- Dry density and watertightness according to Standard NF EN 12467;
- Climatic performance tests according to Standard NF EN 12467.

§	Inspections	Frequencies
C3.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, etc.) Inspection of positioning of the fasteners or inserts (according to the installation)	At each change and random sampling once per shift
C3.2.	Inspection of visual appearance	Each panel
C3.3	Apparent dry density according to Standard NF EN 12467 or wet density (according to in-house method)	Once a week
	Certified characteristics	
C3.4.	Composition Thickness Flexural strength in wet conditions according to Standard NF EN 12467 and Pull-out strength of fasteners or inserts according to DT 15-03 method 1.8	Once a week with recording





#### C4. CEMENT MORTAR AND CLAY SLIPS

#### **Product evaluation method**

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Specifications and test methods according to Standard NF P 13-307;
- Principles and general test procedures for impact tests according to Standard NF P 08-301;
- Adhesive strength of hardened rendering and plastering mortars on clay units according to Standard NF EN 1015-12.

consistency of sen-inspection of production in the factory			
§	Inspections	Frequencies	
C4.0	Check of the colour and appearance of the slips	At each delivery	
C4.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, etc.)	At each change and random sampling once per shift	
C4.2.	Inspection of visual appearance	Each panel	
C4.3	Resistance to impact from a soft body (M50-130J) on an element according to Standard NF P 08-301	Once a month	
	Certified characteristics		
C4.4.	Composition Thickness Adhesive strength of hardened rendering and plastering mortars on clay units according to standard NF EN 1015-12	Once a week with recording	



## D. Clay and ceramic

Reference documents: STANDARD NF EN 1304 (outdoor clay cladding) or STANDARD NF EN 14411 (ceramic tiles)

#### Classification according to the standard

The product class is defined in Standard EN-1304:

- Level for waterproofing of the products: level 1.

The product class for outdoor use according to Standard EN-14411 is defined in § ZA.1.:

- The product can be made by drawing (Group A) or by pressing (Group B);
- Drawn ceramic tiles and panels of Group A la or A lb (E ≤ 3%);
- Pressed ceramic tiles and panels of Group B Ia or B Ib (E ≤ 3%).

For use in built-up cladding products or cladding products, the products in the classes indicated below can be admitted if the frost behaviour of the product has been proven by a flexural strength test after freeze/thaw cycle:

Production method	Group II <sub>a</sub> 3% < E ≤ 6%	Group II <sub>b</sub> 6% < E ≤ 10%
A - Drawn	A II <sub>a</sub> -part 1	A II <sub>b</sub> -part 1
B – Dry pressed	B IIa	B II <sub>b</sub>

- Geometrical characteristics according to Standard NF EN 1024;
- Flexural strength according to Standard NF EN 538;
- Water absorption according to Appendix B of Standard NF EN 539-2;
- Frost resistance according to method C of Standard NF EN 539-2;
- Dimensional characteristics according to Standard NF EN ISO 10545-2;
- Water absorption, apparent porosity and apparent relative density according to Standard NF EN ISO 10545-3;
- Flexural strength according to Standard NF EN ISO 10545-4;
- Moisture expansion according to Standard NF EN ISO 10545-10;
- Freeze-thaw resistance according to Standard NF EN ISO 10545-12.



Consistency of production self-inspection at the factory and/or at the transformer's site

§	Inspections	Frequencies	
D1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, straightness of edges, etc.) Edge profile, dimensions of the fastening lips and the insert notching Water absorption (according to in-house method) Proficiency in installing the anti-fragmenting system for the tiles: inspection of adhesive reactivity, hardness, ratio and quantity Strength test on the anti-fragmentation mesh according to in-house method	At each change and random sampling once per shift	
D2.	Inspection of visual appearance (bursting and cracking, bloom, crazing, etc.)	Each panel	
D3.	Water absorption according to Appendix B of Standard NF EN 539-2 or Water absorption, apparent porosity and apparent relative density according to Standard NF EN ISO 10545-3.  Frost resistance according to method C of Standard NF EN 539-2, followed by: Flexural strength according to Standard NF EN 538, or Freeze-thaw resistance according to Standard NF EN ISO 10545-12 followed by: Flexural strength according to Standard NF EN ISO 10545-4.	Once per quarter	
	Certified characteristics		
D4.	Composition Thickness or weight per linear metre Flexural strength according to Standard NF EN 538, or Flexural strength according to Standard NF EN 10545-4 Pull-out strength of fastening lips according to DT 15-03 method 1.10 or Pull-out strength of the fastening sockets according to DT 15-03 method 1.11 or Tensile pull-out strength of inserts according to DT 15-03 method 1.8	Once a week with recording	



## E. Composite panels and composite panels with metal facing

#### E1. ALUMINIUM SHEET AND POLYURETHANE LAYER COMPOSITE PANEL

#### **Product evaluation method**

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Dimensional tolerances: Appendix D of Standard NF EN 14509;
- Characteristics of the material: Appendix A3 of Standard NF EN 14509, Appendices C3 and C4 of European Technical Approval Guideline no. 16;
- Mechanical properties of aluminium or aluminium alloy sheets, strips and plates according to Standard EN 485-2;
- Chemical composition of aluminium and aluminium alloy according to Standard EN 573;
- Specifications for aluminium and aluminium alloy coil coated sheets and strips according to Standard EN 1396.

consistency of cent inspection of production in the factory		
§	Inspections	Frequencies
E1.0.	For sheet metal: acceptance certificate 3.1. A according to Standard EN 10204	At each delivery
E1.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift
E1.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
E1.3.	Composition Thickness or mass per unit area Flexural shear strength according to Standard NF EN 14509	Once a week with recording



#### E2. ALUMINIUM SHEET AND POLYETHYLENE COMPOSITE PANEL

#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

- Dimensional tolerances: Appendix D of Standard NF EN 14509;
- Characteristics of the material: peel strength according to standard ASTM D-1781, ASTM D 903 or ASTM D-1876, to be adapted depending on the type of core;
- Mechanical properties of aluminium or aluminium alloy sheets, strips and plates according to Standard EN 485-2;
- Chemical composition of aluminium and aluminium alloy according to Standard EN 573;
- Specifications for aluminium and aluminium alloy coil coated sheets and strips according to Standard EN 1396.



## Consistency of factory production self-inspection of manufactured panels

§	Inspections	Frequencies
E2.0.	For sheet metal: acceptance certificate 3.1 A according to Standard EN 10204	At each delivery
E2.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.) Dimensional inspections of cassettes and catches (making cassettes using panels)	At each change and random sampling once per shift
E2.2.	Inspection of visual appearance	Each panel
E2.3.	Peel strength according to standard ASTM D 1781, ASTM D 903 or ASTM D 1876 after heat conditioning (6 hours in boiling water – test on samples at ambient temperature) – unchanged performance.	Once a month
	Certified characteristics	
E2.4.	Composition Thickness or mass per unit area Peel strength according to standard ASTM D 1781, ASTM D903 or ASTM D 1876 after 24 hours.	Once a week with recording

#### Consistency of self-inspection for reprocessing the cassettes

consistency of seminispection for reprocessing the cassettes			
8	Inspections	Frequencies	
E2.5.	Project review, technical files. Placing of component orders	At each project Establish whether the project is covered by the Technical Assessment	
E2.6.	Internal procedures and documented inspections on in-bound deliveries of the elements to be processed, the components and the accessories	At each delivery	
E2.27	Inspection of visual appearance	Each element	
	Certified characteristics		
E2.8.	Functional and dimensional inspections: width, length, size and catch position, flatness, straightness, assembly test.  Machining inspection: angle, depth, residual thickness.	At start-up, at every change in reference produced and every 50 elements	



#### E3. COMPOSITE PANEL OF STEEL SHEET AND VARIOUS CORES

#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Dimensional tolerances: Appendix D of Standard NF EN 14509;
- Characteristics of the material: Appendix A3 of Standard NF EN 14509, Appendices C3 and C4 of European Technical Approval Guideline no. 16.

§	Inspections	Frequencies
E3.0.	For sheet metal: acceptance certificate 3.1. A according to Standard EN 10204	At each delivery
E3.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift
E3.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
E3.3.	Composition Thickness or mass per unit area Flexural force causing a deformation of 1/200 of the span according to DT 15-03 method 2.1 and Strength of inserts according to DT 15-03 method 1.8	Once a week with recording



#### E4. COMPOSITE PANEL OF STONE AND VARIOUS CORES

#### Product evaluation method

The European Standard or the EAD defining the minimum requirements is not available at this time.

Product family comes under an opt-in EAD certification procedure.

The European Guideline ETAG No. 34 concerning exterior cladding kits can be used as one of the test reference documents.

#### Standards available

- Requirements for stone used for cladding according to Standard EN 1469;
- Density and porosity according to Standard NF EN 1936;
- General prescriptions for use of natural stones according to Standard NF B 10-601;
- Flexural strength according to Standard NF EN 12372;
- Frost resistance according to Standard NF EN 12371;
- Breaking load at a dowel hole according to Standard NF EN 13364.

§	Inspections	Frequencies
E4.0.	Documented internal procedure for acceptance inspection of stones  Porosity and apparent density according to Standard NF EN 1936  Flexural strength according to Standard NF EN 12372	At each delivery Once every two years Once every two years
E4.1.	Dimensional inspections (length, width)  Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)  Check of the positioning of the inserts	At each change and random sampling once per shift
E4.2.	Inspection of visual appearance and defects (of the stone)	Each panel
E4.3.	Flexural force causing a deformation of 1/200 of the span according to DT 15-03 method 2.1 or Resistance to perpendicular tensile stress according to DT 15-03 method 2.27	Once a month
	Certified characteristics	
E4.4.	Thickness	Once a week with recording



Resistance to pull-out by perpendicular tensile stress of	
inserts according to DT 15-03 method 1.8	



## F. Thermally modified natural wood

Reference document: NF EN 14915

#### Classification according to the standard

The standard does not define the product class for outside use.

#### Standards available

- Moisture content, density and flexural strength according to Standard NF EN 408;
- Principles of testing and classification of the natural durability of wood according to Standard EN 350-1;
- Dimensional tolerances according to Standard NF EN 13647;
- Moisture content according to Standard EN 13183-1;
- Dimensional stability according to Standard EN 1910;
- Radial and tangential swelling according to Standard ISO 4859.

§	Inspections	Frequencies
F.0.	Documented internal procedure for acceptance inspection of wood	At each delivery
F.1.	Dimensional inspections (length, width) Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	At each change and random sampling once per shift
F.2.	Inspection of visual appearance	Each panel
F.3.	Moisture content according to Standard NF EN 408  Determination of radial and tangential swelling according to Standard ISO 4859	At each loading and random sampling once per shift
	Certified characteristics	
F.4.	Species Thickness or mass per unit length Bending force according to Standard NF EN 408	Once a week with recording



#### G. Natural stone

Reference document: NF EN 1469 (wall cladding in natural stone slips)

#### Requirements

Characteristics	Classes	Tolerance
Namainal thioles and in more	12< to ≤ 30 mm	± 10%
Nominal thickness in mm	30< to ≤ 80 mm	± 3 mm
	e ≤ 50 mm and dimension < 600 mm	± 1 mm
Length and width	e ≤ 50 mm and dimension ≥ 600 mm	± 1.5 mm
	In relation to an edge	± 2 mm
	In relation to the exposed face	± 1 mm
Location of the stud holes	In depth	+ 3 mm / - 1 mm
	Diameter	+ 1 mm / - 0.5 mm

Requirement relative to surface finish: defined under § 4.1.8.

Flexural strength, water absorption, apparent relative density and apparent porosity: no level or performance class required.

- Requirements for stone used for cladding according to Standard EN 1469;
- Water absorption by capillarity according to Standard NF EN 1925;
- Density and porosity according to Standard NF EN 1936;
- General prescriptions for use of natural stones according to Standard NF B 10-601;
- Permeability to water vapour according to Standard NF EN 12524;
- Frost resistance according to Standard NF EN 12371;
- Flexural strength according to Standard NF EN 12372;
- Breaking load at dowel hole according to Standard NF EN 13364;
- Thermal shock resistance according to Standard NF EN 14066;
- Water absorption at atmospheric pressure according to Standard NF EN 13755.



§	Inspections	Frequencies
	Documented internal procedure for acceptance inspection of stones	At each delivery
G.0.	Porosity and apparent density according to Standard NF EN 1936	Once every two years
	Flexural strength according to Standard NF EN 12372	Once every two years
	Dimensional inspections (length, width)	At each change and random
G.1.	Functional inspections (flatness, squareness, mate fitting, straightness of edges, etc.)	sampling once per shift
G.2.	Inspection of visual appearance	Each panel
	Certified characteristics	
G.3.	Thickness Geometrical inspection of the groove (if fitted in continuous rabbet) or Resistance of the catches according to DT 15-03 method 1.9	Once a week with recording